



Montana Department of  
**ENVIRONMENTAL QUALITY**

Marc Racicot, Governor

109 Cooperative Way • Suite 105 • Kalispell, MT 59901-2389 • (406) 755-8985 • FAX (406) 755-8977

Jeffrey A. Pearson  
Eli & Associates, Inc.  
5475 Alloy South  
Missoula, MT 59807

February 14, 2001

Re: EQ 01-1372, Water System Extension, Leufkens Commercial Park

Dear Jeff:


Engineering Report, and plans and specifications submitted on February 8, 2001 with respect to the above referenced project, have been reviewed in accordance with Department design standard DEQ-3, 1999 edition. At this time the plans submitted have been found to meet the requirements of the design standard.

This project consisting of 2575 feet of new 3 inch PVC water main extension to the previously approved Tradewinds Village public water system is located in Sanders County, Montana. Project design report, and plans and specifications were submitted by Andrew C. Fisher, PE # 5311E. This letter acknowledges receipt of as-built record drawings for the above water system and extension.

The review of this application was performed to ensure that the design meets Department of Environmental Quality minimum design standards. The department does not warrant the design, performance or structural integrity of the project by issuance of this approval statement. This approval is given with the understanding that the improvements will be constructed and operated in a manner consistent with the approved plans, specifications, design report, capacity development documents, and department regulations. Failure to construct or operate the system accordingly may be considered a violation of the conditions of this approval.

The Department understands that there is an existing well and pump house not connected to the system at this time. This letter constitutes approval of the construction features of the well and pump house but not connection to the water system. Appropriate water quality and quantity test results and a Source Water Protection and Delineation Report per DEQ-3 must be submitted to this office for review and approval before connection to the system can be made. Thank you for your efforts to meet our requirements. If there is anything I can do to answer questions or assist in the future, please do not hesitate to call me at (406) 755-8985.

Sincerely,

  
Walter M. Lauder  
Environmental Engineering Specialist  
DEQ, Community Services Bureau  
Public Water Supply Section

cc: Sanders County Sanitarian

OCT 02 2001