

Page 2
North Shore Estates III
Sanders County
45-87-L1-17

THAT the bottom of the drainfield shall be at least four feet above the water table, and,

THAT no sewage treatment system shall be constructed within 100 feet of the maximum highwater level of a 100 year flood of any stream lake, watercourse, or irrigation ditch, nor within 100 feet of any domestic water supply source, and,

THAT water supply and sewage treatment systems will be located as shown on the approved plans, and,

THAT plans for any proposed replacement of water and individual sewage treatment systems will be reviewed and approved by the Sanders County Health Department before construction is started, and,

THAT the developer shall provide each purchaser of property with a copy of the Plat, approved location of water supply and sewage treatment system and a copy of this document, and,

THAT instruments of transfer for this property shall contain reference to these conditions, and,

THAT departure from any criteria set forth in the approved plans and specifications and Title 16, Chapter 16, Sub-Chapter 1, 3, & 6 ARM when erecting a structure and appurtenant facilities in said subdivision without Department approval, is grounds for injunction by the Department of Health and Environmental Sciences.

YOU ARE REQUESTED to record this certificate by attaching it to the Plat filed in your office as required by law.

DATED this 19th day of December, 1986.

JOHN J. DRYNAN, M.D.
DIRECTOR

By:

